7364162/2023/VIG-VI-PRR01

GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Public Services - RWS&S - Verification of work "CPWS Scheme to Chindadagaruvu of Amalapuram (M), Bodasakurru of Allavaram (M) and Kunavaram & Bheemanapalli of Uppalaguptam (M), East Godavari District - Disciplinary proceedings against Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District under Rule 20 of Andhra Pradesh Civil Services (Classification, Control & Appeal) Rules, 1991- Article of charges - Issued.

PANCHAYAT RAJ & RURAL DEVELOPMENT (VIG.VI) DEPARTMENT

G.O.Rt.No.265. **Dated 09.05.2023.**

Read with:-

From the Director General, G.A. (V&E) Department, Vigilance Report No.07 (C.No.316/V&E/Engg./2014), dt.19.05.2022.

*****

ORDER:-

It is proposed to hold an enquiry against Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District in accordance with the procedure laid down in Rule 20 of the Andhra Pradesh Civil Services (Classification, Control & Appeal) Rules, 1991.

2. The substance of the imputations of misconduct or mis-behaviour in respect of which the enquiry is proposed to be held is set out in the enclosed statement of article of charge (Annexure-I). A list of documents by which and a list of witnesses by whom, the article of charges are proposed to be sustained are also enclosed as Annexure-II and Annexure-III.

3. Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District is directed to submit written statement of his defence within (90) days of the receipt of this order.

4. Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District is informed that an inquiry will be held only in respect of article of those charges as are not admitted. He should, therefore, specifically admit or deny article of charge.

5. Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District, is further informed that if he does not submit his written statement of defence on or before the period specified in Para 3 above or otherwise fails or refuses to comply with the provisions of Rule 20 of Andhra Pradesh Civil Services (Classification, Control & Appeal) Rules, 1991 read with Rule 9 of AP Revised Pension Rules, 1980 or the orders / directions issued in pursuance of the said rules, the Inquiring Authority may hold the inquiry against him ex-parte.

6. Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District, is invited to Rule 24 of the Andhra Pradesh Civil Services (Conduct) Rules, 1964, under which no Government Servant shall bring or attempt to bring any political or outside influence to bear upon any superior authority to further his interest in respect of matters pertaining to his service under the Government. If any representation is received on his

(Contd...Page 2)

behalf from another person in respect of any matter dealt within these proceedings, it will be presumed that Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram is aware of such a representation and that it has been made at his instance and action will be taken against him for violation of Rule-24 of the Andhra Pradesh Civil Services (Conduct) Rules, 1964.

7. The receipt of this order shall be acknowledged.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

B. RAJSEKHAR,
SPECIAL CHIEF SECRETARY TO GOVERNMENT

To
Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section,
Allavaram, East Godavari District through the Engineer-in-Chief,
RWS&S, Vijayawada.
The Engineer-in-Chief, RWS &S, Vijayawada (in duplicate with a request to serve and return the dated acknowledgement copy)
Copy to:
The G.A.(V&E) Department, Vijayawada.
The Accountant General (A&E), A.P., Vijayawada.
The Secretary to A.P. Vigilance Commission.
SF/SCs.

// FORWARDED :: BY ORDER //

B. Bharath
SECTION OFFICER

7364162/2023/VIG-VI-PRR01

ANNEXURE- I

STATEMENT SHOWING THE ARTICLE OF CHARGES FRAMED AGAINST SRI Y. SRIDHAR, ASSISTANT EXECUTIVE ENGINEER, RWS&S SECTION, ALLAVARAM OF EAST GODAVARI DISTRICT.

CHARGE :-

That Sri Y. Sridhar, Asst.Executive Engineer, RWS&S Section, Allavaram of East Godavari District Recommended for release of deposits without rectification of the subsided part of the retaining wall of Chindadagaruvu SS Tank as suggested by the JNTU College of Engineering, Kakinada by the Contractor for the work "CPWS Scheme to Chindadagaruvu of Amalapuram (M), Bodasakurru of Allavaram (M) and Kunavaram & Bheemanapalli of Uppalaguptam (M), East Godavari District.

B. RAJSEKHAR,
SPECIAL CHIEF SECRETARY TO GOVERNMENT

// FORWARDED :: BY ORDER //

B. Bharati
SECTION OFFICER

7364162/2023/VIG-VI-PRR01

ANNEXURE – II

STATEMENT OF THE IMPUTATION OF MISCONDUCT OR MIS-BEHAVIOUR IN SUPPORT OF EACH ARTICLE OF CHARGE FRAMED AGAINST SRI Y. SRIDHAR, ASSISTANT EXECUTIVE ENGINEER, RWS&S SECTION, ALLAVARAM OF EAST GODAVARI DISTRICT.

BASIS :-

The Director General, (Vig & Enft), General Administration (Vigilance & Enforcement) Department, Vigilance Report No.07 (C.No.316/V&E/Engg/ 2014), dt.19.05.2022 has submitted a detailed report on the Confidential Probe on the Verification of work "CPWS Scheme to Chindadagaruvu of Amalapuram (M), Bodasakurru of Allavaram (M) and Kunavaram & Bheemanapalli of Uppalaguptam (M), East Godavari District". In his enquiry report the Director General (V&E) has reported to the Government that, 1) As per Clause 7.1 of IS 8009 (Part-I) 1976, it is required that a sufficient number of borings be taken up to indicate the limits of various underground strate and to furnish the location of the water table and water bearing strata. Generally, it will be sufficient, if two exploratory holes are located diagonally on opposite corners, unless the proposed structure is small, in which case one borehole at the centre may be sufficient. For large structures, additional boreholes may be driven suitably. But, it was observed that only one soil sample per each work was collected and tested for assessing the Safe Bearing Capacity of soil of SS Tank works of CPWS Scheme to Chindadagaruvu and CPWS Scheme to Kunavaram.

The defects were identified during the defect liability period of the work and the same should have been rectified by the agency as suggested by the Department. But the defects were not rectified by the agency as per the remedial measures suggested by the JNTU College of Engineering, Kakinada instead earthen bund was provided for a length of 56mts, which reduced the capacity of tank to an extent of 1176 cum. Sri Y. Sridhar, Assistant Executive Engineer, RWS&S Section, Allavaram has Recommended for Payment of deposits without rectification of the subsided part of the retaining wall of Chindadagaruvu SS Tank as suggested by the JNTU College of Engineering, Kakinada. From this it is evident that Sri Y. Sridhar, Assistant Executive Engineer, RWS&S Section, Allavaram of East Godavari District has violated Rules 3(1), 3(2), of AP Civil Services Conduct Rules, 1964 for lack of devotion to duty, lack of integrity, lack of impartially and for behaving in a manner unbecoming of a Government employee.

Hence the charge.

B. RAJSEKHAR,
SPECIAL CHIEF SECRETARY TO GOVERNMENT

// FORWARDED :: BY ORDER //

B. Bharathi
SECTION OFFICER

7364162/2023/VIG-VI-PRR01

ANNEXURE – III

LIST OF THE DOCUMENTS BY WHICH THE ARTICLE OF CHARGES FRAMED AGAINST SRI Y. SRIDHAR, ASSISTANT EXECUTIVE ENGINEER, RWS&S SECTION, ALLAVARAM OF EAST GODAVARI DISTRICT.

1. From the Director General, G.A. (V&E) Department, Vigilance Report No.07 (C.No.316/V&E/Engg/2014), dt.19.05.2022.

B. RAJSEKHAR,
SPECIAL CHIEF SECRETARY TO GOVERNMENT

// FORWARDED :: BY ORDER //

B. Bharati
SECTION OFFICER

ANNEXURE- IV

LIST OF WITNESSES BY WHICH THE ARTICLE OF CHARGES ARE FRAMED AGAINST SRI Y. SRIDHAR, ASSISTANT EXECUTIVE ENGINEER, RWS&S SECTION, ALLAVARAM OF EAST GODAVARI DISTRICT.

- NIL –

B. RAJSEKHAR,
SPECIAL CHIEF SECRETARY TO GOVERNMENT

// FORWARDED :: BY ORDER //

B. Bharati
SECTION OFFICER